

**Mandatory Language for a Maximum Contaminant Level Violation  
MCL, AVERAGE / ARSENIC-FLUORIDE**

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF NEW HOME PWS (1530004) public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for arsenic. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic to be 0.010 milligrams per liter (mg/L) based on the running annual average (RAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in the:

**ARSENIC:**

Monitoring Period / Sample Point	Contaminant Level	Location
4Q2025 EP001	0.019 mg/L	BEHIND 211 N MAIN ST, NEW HOME
3Q2025 EP001	0.019 mg/L	BEHIND 211 N MAIN ST, NEW HOME
2Q2025 EP001	0.018 mg/L	BEHIND 211 N MAIN ST, NEW HOME

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: <corrective action>

**Arsenic:**

*We are currently in discussions with our Engineers about getting a Reverse R/O System to elevate this issue. As soon as we find funding, we will start planning.*  
<corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: Lory Needham

Area code + phone number: 906-924-7514

Posted date / Delivered on 1-29-26

**Instructions for preparing the required Public Notice:**

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

**Public Notice delivery timelines:**

The initial public notice shall be issued as soon as possible, but in no case later than 30 days after the violation was identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.



Texas Commission on Environmental Quality  
*Protecting Texas by Reducing and Preventing Pollution*

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS) name: CITY OF NEW HOME PWS ID: 1530004  
Type violation/Compliance Period: MCL ARSENIC 2Q2025 - 4Q2025  
The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122; and

Made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

- Posting the PN on the internet at www.cityofnewhome.com
- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- Posting the PN in public places
- Posting the PN in conspicuous places within the service area
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- Email notification

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Name (print) Lory Needham

Title: Water Superintendent

Phone: 806-924-7514

Date of Delivery: 1-29-26

Signature: Lory Needham

Date signed: 1-29-26

Reply to this email with completed, signed and dated copies of all documents for our review.