

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, AVERAGE / FLUORIDE**

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF NEW HOME TX1530004 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for fluoride. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for fluoride to be 4.0 milligrams per liter (mg/L) based on running annual average (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for fluoride indicates a compliance value in quarter two 2023 of 4.4 mg/L for EP001.

This is not an emergency. However, some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

An alternate source of water should be provided to the affected population, which consists of children less than nine years old. The alternate water should be used for drinking and cooking only. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

We are currently in the planning and funding stage of implementing a R/O system to control this issue.

<corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Cory Needham at
(806) 445-1209. <water system official's name>
<area code + phone number>

Posted /Delivered on: 08/16/2023
<Date Posted>

Instructions for preparing the required Public Notice:

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than 90 days after the violation was identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.